

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 8110-2042:0004 Page 1 of 1

CATEGORY: 8110 -- DECKING FOR WILDLAND URBAN INTERFACE (W.U.I)

LISTEE: AZEK BUILDING PRODUCTS 801 East Corey Street, Scranton, PA 18505
Contact: Michael Fiume (330) 618-8514 Fax (251) 943-2917
Email: michael.fiume@ctgpb.com

DESIGN: "AZEK Deck" - "Harvest, Arbor and Terra Collections" composite deck board, all colors, 1" thick x 3.5" width or 5.5" width. Refer to the manufacturer's installation instructions and product data sheets.

RATING: Class B Flame Spread.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee name. Model number, rating and SFM label.

APPROVAL: Listed as decking materials for use in the Wildland Urban Interface areas.

NOTE: Test Protocol SFM 12-7A-4A.

1-23-13 il



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 20, 2018**

Listing Expires **June 30, 2019**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division