



September 14, 2015

Mr. Chip Herr  
CPG Building Products  
894 Prairie Avenue  
Wilmington, OH 45177

RE: Summary Letter on ASTM E84 Performance of Deck Boards

Dear Mr. Herr,

This letter is in response to a request for a summary of the surface burning performances of deck board product tested by Intertek-ATI and provided by CPG Building Products.

A detailed description of the testing can be found in Intertek-ATI Test Report E7507.02-121-24. This letter does not imply certification of the products by Intertek-ATI.

**Project Summary:**

Report Number:

- E7507.02-121-24

Report Holder:

- CPG Building Products

Test Laboratory:

- Architectural Testing, Inc. an Intertek company (“Intertek-ATI”)

Performance Standard:

- ASTM E84-15a, *Standard Test Method for Surface Burning Characteristics of Building Materials*

Test Date:

- June 17, 2015

Description of Product Tested:

- Product Type – Deck Boards
- Series/Model – Vintage Decking
- Size – Eight, 5-1/2 in. wide by 144 in. long x 1 in. thick boards
- Side to Flame – Walking Surface
- Mounting Method – ¼ in. diameter steel rods spaced 24 in.

Summary of Results:

- Flame Spread Index = 25
- Smoke Developing Index = 750

For a more detailed description of temperature data, flame propagation distances, product information, test observations, and photographs, please reference the full test report.

Sincerely yours,

---

Matthew D. Freeborn  
Manager - Fire Testing

MDF:ddr